

Moisture meter

Operating manual

BLO online analysing device with wood chips sensor

for measuring the moisture content of wood chips



78,0 °F | 6,16% | 456kg/m³ | -27,3td | 0,64aw | 51,9%r.H. | 14,8%abs | 100,4g/m² | 09m/s | 4,90Ug/L | 1


Your BLO device at a glance

The main unit




No.	Name
1	Aluminium housing for electronics
2	Display
3	Keypad

Overview plugs




No.	Name
1	Power input 24 VDC & analogue output
2	Ground screw
3	BNC sensor plug
4	Push-Pull sensor plug

Overview plugs option 100 - 240 VAC art.no. 12215



No.	Name
1	Power input 100 - 240 VAC
2	Analogue output
2	Ground screw
3	BNC sensor plug
4	Push-Pull sensor plug

The display



No.	Name
1	Calibration curve
2	Moisture content in % (" 6.3 How moisture content is defined ")
3	Display symbols
4	Temperature display

The display symbols


Symbol	Name
	Enter
	Up
	Down
	Back
	Enter numbers
	Enter letters
	Continue / go right

Symbol	Name
	Left
	Yes
	No
	Change input level
	OK
	Change menu
	On/off button

The menus

The device has three different menus: product selection, Data Log and main menu:

Product selection menu



No.	Name
1	Change menu
2	Device on/off
3	For changing the calibration curve


Main menu

The main menu comprises the following menu items:

- **Options:**
Language, Unlock, °C/°F, Averaging, BL On Time, Materialcalibration, Password, Reset
- **Status**


Your wood chips sensor art.no. 12122 at a glance

The wood chips sensor



No.	Name
1	BNC sensor plug
2	Push-Pull sensor plug

The wood chips sensor



No.	Name
1	Sensor surfaces

Table of contents

Your BLO device at a glance	2
The main unit	2
Overview plugs	3
Overview plugs option 100 - 240 VAC art.no. 12215	3
The display symbols	4
The menus	5
Your wood chips sensor art.no. 12122 at a glance	6
The wood chips sensor	6
The wood chips sensor	6
1. Introduction	10
1.1 Information about this operating manual	10
1.2 Limitation of liability	10
1.3 Symbols used in this manual	11
1.4 Customer service	11
2. For your safety	12
2.1 Proper use	12
2.2 Improper use	12
2.3 User qualifications	12
2.4 General safety information	12
2.5 Warranty	13
3. On receipt of your device	13
3.1 Taking the device out of its packaging	13
3.2 Making sure that all of the components have been included	13
3.2.1 Scope of supply	13
4. Installation of the wood chips sensor	14
4.1 Laying of the supply line or transmission line	14
4.2 Mounting the sensor	14
4.3 Measuring principle	15
4.4 Mounting the analysing device	15
4.5 Connecting the sensor cables	15
4.5.1 Push-Pull plug	15
4.5.2 BNC plug	15
4.6 Disconnecting the sensor cables	16

4.6.1	Push-Pull plug	16
4.6.2	BNC plug	16
4.7	Pin assignment	16
4.8	Wiring diagram	17
4.9	Wiring diagram option 100 - 240 VAC art.no. 12215	17
5.	Using the device - Basics	18
5.1	Selecting the calibration curve	18
5.2	Taking a measurement	18
6.	Calibration curves	19
6.1	Definition wood chip types (in accordance with EN ISO 17225-1)	19
6.2	Selection of calibration curve for wood chips	20
6.2.1	Wood chips	20
6.2.2	Coarse wood chips	20
6.2.3	Industrial wood chips	21
6.2.4	Fine wood chips	21
6.3	How moisture content is defined	26
7.	Checking the device's status	26
8.	Configuring the device	27
8.1	Selecting a language	27
8.2	Activating options	27
8.3	Deactivating options	28
8.4	Selecting °C/°F	28
8.5	Setting the averaging time	29
8.6	Configuring the display illumination time	29
8.7	Configuring the material calibration function	30
8.8	Changing the password	30
8.9	Resetting the device to its factory settings	31
9.	Cleaning and maintenance	31
9.1	Care instructions	31
9.2	Cleaning the device	31
10.	Faults	32
11.	Repair	33
12.	Storage and disposal	33
12.1	Storing the device	33

12.2	Disposing of the device	33
13.	Device information	34
13.1	EC declaration of conformity	34
13.2	Technical data	38
13.3	Technical drawing wood chips sensor	39

1. Introduction

1.1 Information about this operating manual

This operating manual is designed to enable you to use the BLO safely and effectively. It is part of the device, has to be stored nearby and must be easily accessible to users at all times.

All users are required to carefully read and make sure that they have understood this operating manual before using the BLO. All of the safety and operating instructions detailed in this manual have to be observed to ensure the safety of the device.

1.2 Limitation of liability

All of the information and instructions provided in this operating manual have been compiled on the basis of the current standards and regulations, the state of the art, and the extensive expertise and experience of Schaller Messtechnik GmbH.

Schaller Messtechnik GmbH does not accept any liability for damage associated with the following, which also voids the warranty:

- Non-observance of this operating manual
- Improper use
- Inadequately qualified users
- Unauthorised modifications
- Technical changes
- Use of unapproved spare parts

This fast measuring procedure can be affected by a range of different factors. For this reason, we recommend periodically checking the device's measurements with a standardised oven-drying method.

We, as the manufacturer, do not accept any liability for any incorrect measurements and associated consequential damage.

1.3 Symbols used in this manual

All of the safety information provided in this manual is shown with a corresponding symbol.



ATTENTION

It is essential to observe this warning. Non-compliance can lead to damage to property or equipment.



Information

This symbol indicates important information that enables users to use the device more efficiently and cost-effectively.

1.4 Customer service

For technical advice, please contact our customer service department at:

Schaller Messtechnik GmbH

Max-Schaller-Straße 99
A - 8181 St.Ruprecht an der Raab

Telephone: +43 (0)3178 28899
Fax: +43 (0)3178 28899 - 901

E-mail: info@humimeter.com
Internet: www.humimeter.com



© Schaller Messtechnik GmbH 2026

2. For your safety

The device complies with the following European directives:

- Restriction of Hazardous Substances in Electrical and Electronic Equipment (RoHS)
- Electromagnetic compatibility (EMC)

The device corresponds to state-of-the-art technology. However, it is still associated with a number of residual hazards.

These hazards can be avoided through strict observance of our safety information.

2.1 Proper use

- Online measurement of the water content and temperature of wood chips by installation of a sensor in the material flow
- Fully calibrated system with calculation of the measuring value by the transmitter unit

2.2 Improper use

- The device must not be used in ATEX.

2.3 User qualifications

The device must only be operated by people who can be expected to reliably take the measurements. The device must not be operated by people whose reaction times may be slowed due to, e.g. the use of drugs, alcohol or medication.

All persons using this device must have read, understood and follow the instructions provided in the operating manual.

2.4 General safety information

The following safety information has to be observed at all times to avoid damage to objects and injury to people:

- In case of damages or loose parts on the device, contact Schaller Messtechnik GmbH or your dealer.

All of the device's technical features have been inspected and tested before delivery. Every device has a serial number. Do not remove the tag with the serial number.

2.5 Warranty

The warranty does not apply to:

- Damage resulting from non-observance of the operating manual
- Damage resulting from third-party interventions
- Products that have been used improperly or modified without authorisation
- Products with missing or damaged warranty seals
- Damage resulting from force majeure, natural disasters, etc.
- Damage from improper cleaning

3. On receipt of your device

3.1 Taking the device out of its packaging

- Take the device out of its packaging.
- Next, make sure that it is not damaged and that no parts are missing.

3.2 Making sure that all of the components have been included

Make sure that all of the components have been included by checking the package contents against the following list:

3.2.1 Scope of supply

- BLO analysing device
- Wood chips sensor
- Connecting cable of 1.9 m length
- BNC sensor cable with 5 metre length
- Push-pull sensor cable with 5 metre length
- Operating manual

Optional accessories:

- 100 - 240 VAC power supply
- Ethernet interface
- Test block

4. Installation of the wood chips sensor

4.1 Laying of the supply line or transmission line


- The cable must not be laid in the area of interference fields.
- Do not operate the sensor in the area of electromagnetic interference fields.
- The cable must not be bent excessively.
- The permissible cross-sections for the installation must be observed.
- The cable length must be kept as short as possible.
- » If an extension of the cable is required, the cross-section of the extension must not be below 0.25 mm².

4.2 Mounting the sensor

- During the measurement a continuous contact between the stainless metal sensor surfaces and the material being measured has to be ensured.
- For a correct measurement result, the product must exert a pressure of at least 20 N/dm² onto the sensor surfaces.
- There must be no contact of any conductive materials with the sensor surfaces.
- Mount the sensor on the four drilled holes (Ø 9.0 mm) in the sensor block.

Possible mounting locations:

- Screw conveyor
 - » Installation at the bottom of the trough
- In-feed chute with hydraulic ram
 - » Installation at the side wall
- Bunker
 - » Installation at the side wall (to ensure the minimum pressure, the sensor possibly has to be mounted at an angle)



Note for installation after the dryer:


After the drying process the material surface is much dryer than its core. Therefore an installation directly after the dryer will lead to too low measuring values. The specified minimum measuring range of 10% water content (for wood chips) will not be possible, in fact the measuring range limit is higher.

4.3 Measuring principle

The BLO with wood chips sensor (art.no. 12122) uses a conductance measurement specially developed by Schaller Messtechnik GmbH. This principle is based on the fact that electrical conductivity changes according to the moisture content of a porous material. Electrical conductivity in dry material is lower than in wet material. The analysing device converts the measured conductance value into weight percent and shows the water content on the display.

4.4 Mounting the analysing device


1. Pre-mount the setscrews.
2. Mount the wall bracket using 4 countersunk screws (Ø 5.0 mm).
3. Place the analysing device into the wall bracket.
4. Fix the analysing device to the wall bracket using the pre-assembled setscrews.



4.5 Connecting the sensor cables


4.5.1 Push-Pull plug

- To connect the plug, simply press it onto the socket (figure 1).
- » Pay attention to the elevations in the plug and their correct positioning (figure 2).



4.5.2 BNC plug

- Connect the plug to the socket and tighten it clockwise with a quarter turn.
- » Pay attention to the elevation at the socket and the guides in the plug and their correct positioning (figure 3).
- » The plug engages noticeably at the end of the guides.



4.6 Disconnecting the sensor cables

4.6.1 Push-Pull plug

- To disconnect the plug of the sensor cable pull the black sleeve off the device (figure 4).




4.6.2 BNC plug

- Push the plug towards the device with little force and turn it counterclockwise with a quarter turn to the beginning of the guides (figure 5).
- Now pull the plug straight off the device.



4.7 Pin assignment



Cable color	Pin no.	Function
Brown	1	Power supply V- (0 VDC) Ground current output
White	2	Power supply V+ (24 VDC)
Blue	3	Analogue output humidity 4 - 20 mA
Black	4	n.c.
Grey	5	Analogue output temperature 4 - 20 mA
Purple	Housing	Equipotential bonding GND




ATTENTION

Damage to the electronics due to incorrect cable connection


Incorrectly connected cables can lead to severe damage of the electronics.

- Connect all cables correctly.

4.8 Wiring diagram



4.9 Wiring diagram option 100 - 240 VAC art.no. 12215



5. Using the device - Basics

5.1 Selecting the calibration curve

To do so: The device has to be in the product selection menu (figure 6).

For an overview of the different calibration curves and the criteria for selecting them, please refer to "6. Calibration curves"

1. Press the  or  button to move from one calibration curve to the next **Or**
2. Press the  or  button for 3 seconds to open the calibration curve overview (figure 7).
3. Use the arrow keys to move from one calibration curve to the next
4. and keep any of them pressed to scroll through the types.
5. Confirm your selection by pressing .



» The calibration curve you selected will now be shown at the top of the display.

5.2 Taking a measurement

- In order to obtain current measuring values, the device must be in the measuring window.

6. Calibration curves

Calibration curve	Material	Measuring range
Fine woodchips	Fine woodchips P16	10 % - 50 %
Woodchips	Woodchips P31 to P45	10 % - 50 %
+ Woodchips	Woodchips P31	10 % - 50 %
Coarse chips	Coarse chips P45	10 % - 50 %
+ Coarse chips	Coarse chips P45	10 % - 50 %
Industrial wood chips	Industrial wood chips P63	10 % - 50 %
+ Industrial wood chips	Industrial wood chips P63	10 % - 50 %
Test block	! Only for testing the moisture meter !	
Reference	! Only for testing the moisture meter !	
0% = 4mA	! Only for testing the analogue output !	
80% = 20mA	! Only for testing the analogue output !	

The calibration curves marked with a plus sign show a higher measuring value.

6.1 Definition wood chip types (in accordance with EN ISO 17225-1)

The given numbers refer to the particle sizes that fit through the round screen openings.

- P16 at least 75 % of the mass between 3.15 and 16 mm
- P31 at least 75 % of the mass between 8 and 31.5 mm
- P45 at least 75 % of the mass between 8 and 45 mm
- P63 at least 75 % of the mass between 8 and 63 mm

6.2 Selection of calibration curve for wood chips

The calibration curves for wood chips depends on the wood type (hardwood, softwood), the size of the chips (size classes according to norm EN ISO 17225-1) as well as on the content of fine fraction.

If you are not sure which calibration curve is the best suited for your material, it is recommended to carry out a reference measurement by kiln-drying (according to EN ISO 18134-2).

Schaller Messtechnik GmbH will be happy to advise you on the selection of the right calibration curve. Please send a picture of your wood chips, placing a measuring tape to the material, to support@schaller-gmbh.at. You will receive a recommendation from us immediately.

6.2.1 Wood chips

For wood chips with fine fraction, mainly consisting of hardwood (maximum proportion of softwood of 30 %). For wood chips sizes from P31 to P45. The fine fraction mainly derives from barks, small branches and bushes. See example pictures [8](#) and [9](#).

If your wood chips don't contain small parts (few fine fraction or no fine fraction) or if the wood chips contain a higher proportion of softwood, use one of the following calibration curves.

6.2.2 Coarse wood chips

For coarse wood chips without fine fraction, mainly consisting of hardwood (maximum proportion of softwood of 30 %). This curve also has to be used for wood chips with fine fraction, mainly consisting of softwood, with a proportion of softwood (spruce, fir, pine, larch) of 70 % and more. For wood chips sizes from P31 to P63. See example pictures [10](#) and [11](#).

If your wood chips mainly consist of softwood and don't contain small parts (few fine fraction or no fine fraction), use the following calibration curve.

6.2.3 Industrial wood chips

For coarse wood chips without fine fraction, mainly consisting of softwood, with a proportion of softwood (spruce, fir, pine, larch) of 70 % and more. For wood chips sizes from P45 to P63. This curve is predominantly suited for measuring wood chips deriving from logs and full trees as well as sawmill residues without fine fraction. See example pictures [12](#) and [13](#).

6.2.4 Fine wood chips

For fine wood chips with a high proportion of fine fraction, consisting of at least one third hardwood. The fine fraction mainly derives from barks, small branches and bushes. For wood chips size P16. See example pictures [14](#) and [15](#).

Example pictures wood chips



Example pictures coarse wood chips



Example pictures industrial wood chips



Example pictures fine wood chips



6.3 How moisture content is defined


The device measures and shows the material’s moisture content. The moisture content readings it displays are calculated in relation to the material’s overall mass:

$$\%WG = \frac{M_n - M_t}{M_n} \times 100$$

- M_n: Mass of the sample with average moisture content
- M_t: Mass of the sample with zero moisture content
- %WG: Moisture content (in accordance with EN ISO 18134-2)

7. Checking the device's status

- 1. Press  twice or hold for 2 seconds.
- 2. Select **Status**. To do so, press  or  and confirm by pressing .
 - » The display will then show the status indicator **humimeter**.
 - » The display will show the following information:



No.	Name
1	Serial number
2	Software version
3	Battery status
4	Memory status

- 3. Confirm by pressing .
- 4. Press  to leave the main menu.

8. Configuring the device



8.1 Selecting a language

1. Press  twice or hold for 2 seconds.
2. Select **Options**. To do so, press  or  and confirm by pressing .
3. Select **Language**. To do so, press  or  and confirm by pressing .
4. Navigate to the required language. To do so, press  or  and confirm by pressing .
- » The settings have been saved.
5. Press  to leave the **Options** menu.
6. Press  to leave the main menu.

8.2 Activating options

To do so: Some of the options must be deactivated.

1. Press  twice or hold for 2 seconds.
2. Select **Options**. To do so, press  or  and confirm by pressing .
3. Select **Unlock**. To do so, press  or  and confirm by pressing .
- » The display will now appear as shown in figure 16.
- » On delivery, the four-digit password is the device's serial number.
4. **Inputting numbers:**
Press and hold  to quickly scroll to the required number and either press it for 3 seconds or press  to confirm the selected number (figure 17).



5. **Moving back:**

Press  to switch to another input level.
To move back, press .

6. Confirm the four-digit password by pressing **OK**.

» The setting has been saved.

» The **°C/°F, Averaging, BL On Time, Materialcalibration, Password, Reset** options are now activated

7. Press to leave the **Options** menu.

8. Press to leave the main menu.

8.3 Deactivating options

Once the device has been switched restarted, the **C/°F, Averaging, BL On Time, Materialcalibration, Password, Reset** options will be deactivated again.

8.4 Selecting °C/°F

To do so: All of the options must be activated (see "8.2 Activating options").

1. Press twice or hold for 2 seconds.

2. Select **Options**. To do so, press or and confirm by pressing .

3. Select **°C/°F**. To do so, press or and confirm by pressing .

4. Navigate to the required temperature scale, i.e. Celsius (°C) or Fahrenheit (°F). To do so, press or and confirm by pressing .

» The setting has been saved.

5. Press to leave the **Options** menu.

6. Press to leave the main menu.

8.5 Setting the averaging time

To do so: All of the options must be activated (see "8.2 Activating options").

1. Press  twice or hold for 2 seconds.
2. Select **Options**. To do so, press  or  and confirm by pressing .
3. Select **Averaging**. To do so, press  or  and confirm by pressing .
4. Navigate to the desired time period in which the arithmetic average is to be calculated (90 seconds/45 seconds/20 seconds/7 seconds/5 seconds). To do so, press  or  and confirm by pressing .
- » The setting has been saved.
5. Press  to leave the **Options** menu.
6. Press  to leave the main menu.

8.6 Configuring the display illumination time

To do so: All of the options must be activated (see "8.2 Activating options").

1. Press  twice or hold for 2 seconds.
2. Select **Options**. To do so, press  or  and confirm by pressing .
3. Select **BL On Time**. To do so, press  or  and confirm by pressing .
4. Navigate to the required setting, turned off (**0 Off**) or turned on (**1 On**). To do so, press  or  and confirm by pressing .
- » The setting has been saved.
5. Press  to leave the **Options** menu.
6. Press  to leave the main menu.

8.7 Configuring the material calibration function

The type calibration function is described in a separate operating manual.

8.8 Changing the password

To do so: All of the options must be activated (see "8.2 Activating options").

1. Press  twice or hold for 2 seconds.
2. Select **Options**. To do so, press  or  and confirm by pressing .
3. Select **Password**. To do so, press  or  and confirm by pressing .
 - » The display will show the current password.
4. Overwrite the current password. To do so, press and hold  to quickly scroll to the required number and either press it for 3 seconds or press  to confirm the selected number.

Moving back:

Press  to switch to another input level.



To move back, press .

5. Confirm the new four-digit password by pressing .
 - » The setting has been saved.
6. Press  to leave the **Options** menu.
7. Press  to leave the main menu.

8.9 Resetting the device to its factory settings

To do so: All of the options must be activated (see "8.2 Activating options").

1. Press  twice or hold for 2 seconds.
2. Select **Options**. To do so, press  or  and confirm by pressing .
3. Select **Reset**. To do so, press  or  and confirm by pressing .
 - » The display will then show the message **Reset?** (figure 18).
4. Confirm by pressing .
 - » The device will now be reset to its factory settings. All of your personal settings will be lost.
 - » The display will show the status indicator **humimeter** (figure 19).
 - » Resetting the device will not affect the saved measuring values.



9. Cleaning and maintenance

Regularly cleaning and maintaining the device will ensure that it will have a long service life and stay in good condition.

9.1 Care instructions

- Do not immerse the sensor in water.
- Do not expose the device to extreme temperatures.
- Do not bend the sensor cable excessively. Repeated bending of the sensor cable can lead to a damage of the sensor.
- Protect the device from strong mechanical shocks and loads.

9.2 Cleaning the device

Sensor surface

Clean the sensor surface with a cloth and cleaning alcohol.

10. Faults

If the measures listed below fail to remedy any faults or if the device has faults not listed here, please contact Schaller Messtechnik GmbH.

Fault	Cause	Remedy
Measuring error	The temperature of the material being measured is too low or high. I.e. the material's temperature is lower than 0 °C or higher than +70 °C	The temperature of the material being measured has to be between 0 °C and +70 °C.
	Measurement error due to too short temperature adjustment time	Let the device adjust to the surroundings.
	Frozen material or material mixed with snow Accuracy decreases significantly	The material must not be frozen or mixed with snow.
	Mouldy or rain wet material Accuracy decreases significantly	Only measure dry, not mouldy material.
	Air value being displayed	If there is no material above the sensor, the air value will be displayed (5.5 %).
	Uneven pressure of the material	Make sure that the material exerts a pressure of at least 20 N/dm ² onto the metal sensor plates.
	Polluted sensor	Clean the metal sensor plates (see "9.2 Cleaning the device").
	Conductive material on the sensor plates	Make sure that there is no contact of any conductive material with the sensor plates.
	The sensor plug is not connected correctly	Make sure that the sensor plug is connected properly.

11. Repair

If your humimeter needs repair, please pack it securely for transport and send it to:
Schaller Messtechnik GmbH
Max-Schaller-Straße 99
A - 8181 St. Ruprecht an der Raab

Download the repair form at humimeter.com/reparatur. Please fill out the form completely and enclose it with your package. This will allow us to clearly identify your repair request and process it quickly.



WARNING

For safety reasons, deeply discharged, damaged, or swollen rechargeable or non-rechargeable batteries are not allowed to be sent. Rechargeable and non-rechargeable batteries must be removed from the device before sending.

12. Storage and disposal

12.1 Storing the device

The device must be stored as follows:

- Avoid mechanical shocks/loads
- Storage temperature: -20 °C to +60 °C

12.2 Disposing of the device



Devices marked with this symbol are subject to Directive 2012/19/ EU of the European Parliament and of the Council of 4 July 2012 on waste electrical and electronic equipment (WEEE).
If the device is being operated outside the European Union, the national regulations on the disposal of such devices that apply in the country of use must be observed.

Electronic devices must not be disposed of as domestic waste.

The device must be disposed of appropriately using appropriate collection systems.

13. Device information

13.1 EC declaration of conformity

KONFORMITÄTSERKLÄRUNG DECLARATION OF CONFORMITY

Name/ Adresse des Herstellers: **Schaller Messtechnik GmbH**
Name/ address of manufacturer: **Max-Schaller-Straße 99**
A – 8181 St. Ruprecht

Produktbezeichnung: **humimeter**
Product designation:

Typenbezeichnung: **BLO ; BLO inkl. BLO-LC, BLO-LW**
Type designation:

Produktbeschreibung: **Messgerät zur Bestimmung des Wassergehalts in Biomasse**
Product description **Measuring device for determining the water content in biomass**

Das bezeichnete Produkt erfüllt die Bestimmungen der Richtlinien:
The designated product is in conformity with the European directives:

EMV - Richtlinie 2014/30/EC	EMC Directive 2014/30/EU
RoHS - Richtlinie 2011/65/EG	RoHS-Directive 2011/65/EU
Niederspannungsrichtlinie 2014/35/EU	Low Voltage Directive 2014/35/EU

Die Übereinstimmung des bezeichneten Produktes mit den Bestimmungen der Richtlinien wird durch die vollständige Einhaltung folgender Normen nachgewiesen:

Full compliance with the standards listed below proves the conformity of the designated product with the provisions of the above-mentioned EC Directives:

EN 61326-1:2013	Elektrische Mess-, Steuer-, Regel- und Laborgeräte - EMV-Anforderungen <i>Electrical equipment for measurement, control, and laboratory use – EMC requirements</i>
------------------------	---

EN IEC 63000:2019-05 ersetzt / replaced EN 50581:2012	Technische Dokumentation zur Beurteilung von Elektro- und Elektronikgeräten hinsichtlich der Beschränkung gefährlicher Stoffe. <i>Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances.</i>
--	--

EN ISO 12100:2011
EN ISO 12100:2013

Allgemeine Gestaltungsleitsätze - Risikobeurteilung und
Risikominderung
*Safety of machinery - General principles for design - Risk as-
sessment and risk reduction*

Für das angeführte Produkt ist eine vollständige Dokumentation mit Betriebsanleitung in Originalfas-
sung vorhanden.

*For the above mentioned product a complete documentation with manual of instruction in original
version is available.*

Bei Änderungen, die nicht vom Hersteller spezifiziert sind, verliert diese Konformitätserklärung
die Gültigkeit.

*In case of any changes not agreed upon with the manufacturer, this declaration of conformity loses its
validity.*

St. Ruprecht a.d. Raab, 31.07.2022


 **Schaller**
Messtechnik / Instrumentenbau
Schaller Messtechnik GmbH
Maunz - St. Ruprecht a.d. Raab 99
AT - 818 | St. Ruprecht a.d. Raab
www.humimetre.com | info@humimetre.com
.....
Bernhard Maunz
Rechtsverbindliche Unterschrift des Ausstellers
Legal binding signature of the issuer



DECLARATION OF CONFORMITY

Name/ address of manufacturer: **Schaller Messtechnik GmbH
Max-Schaller-Straße 99
A – 8181 St. Ruprecht**

Product designation: **humimeter**

Type designation: **BLO ; BLO inkl. BLO-LC, BLO-LW**

Product description **Measuring device for determining the water content
in biomass**

The designated product is in conformity with the following directives:

- **Electromagnetic Compatibility Regulations 2016 Great Britain**
- **RoHS-Directive 2011/65/EU Directive on the restriction of the use of certain hazardous substances in electrical and electronic equipment**
- **Supply of Machinery (Safety) Regulations 2008 Great Britain**

Full compliance with the standards listed below proves the conformity of the designated product with the provisions of the above-mentioned Directives:

EN 61326–1:2013	Electrical equipment for measurement, control, and laboratory use – EMC requirements
EN IEC 63000:2019-05 replaced EN 50581:2012	Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances.
EN ISO 12100:2011 EN ISO 12100:2013	Safety of machinery - General principles for design - Risk assessment and risk reduction

For the mentioned product, a complete documentation with manual of instruction in original version is available.


In case of any changes not agreed upon with the manufacturer, this declaration of conformity loses its validity.

St. Ruprecht a.d. Raab, 31.07.2022


 **Schaller**
Messchick / Humimeter.com
Schaller Messtechnik GmbH
Ma - Schaller-Str. 99
AT - 8180 St. Ruprecht a.d. Raab
www.humimeter.com | info@humimeter.com
.....
Bernhard Maunz
Legal binding signature of the issuer

13.2 Technical data

Measuring range moisture content	10 % to 55 %
Measuring range temperature	-10 °C to +70 °C
Material temperature	0 °C to +70 °C
Operating temperature BLO	0 °C to +50 °C
Outputs	Moisture content (4 - 20 mA) -Scaling (0 % to 80 %) Temperature (4 - 20 mA) -Scaling (-10 °C to +70 °C) Working resistance < 500 Ohm (UB 24 V)
Temperature compensation	Automatic
Power supply	24 VDC (18 to 29 VDC) (optional 100 - 240 VAC)
Current consumption	100 mA (without output)
Electrical connection	Connecting cable 1.9 m
Menu languages	English, German, French, Italian, Spanish, Portuguese, Czech, Polish, Russian, International
Display	128 x 64 illuminated matrix display
Aluminium housing dimensions	250 x 185 x 75 mm (without cable)
Aluminium housing weight	1.1 kg (without cable)
Aluminium housing IP rating	IP 54
Sensor dimensions	188 x 82 x 39 mm (without cable)
Sensor weight	700 g (without cable)
Sensor IP rating	IP 54



Schaller Messtechnik develops, produces and sells professional moisture meters and turnkey solutions.

Schaller Messtechnik GmbH

Max-Schaller-Straße 99, A - 8181 St. Ruprecht an der Raab

Tel +43 (0)3178 - 28899 , Fax +43 (0)3178 - 28899 - 901

info@humimeter.com, www.humimeter.com